



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # : 12-WB-09892

Report To JERICO UNDERHILL WATER
ATTN OF MARC MAHEUX
Address PO BOX 174

UNDERHILL, VT 05489

WSID VT0005096
Account Name JERICO UNDERHILL WATER
Date Received 01/02/2014
Time Received 15:25
Approved Date 01/03/2014

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	01/02/2014	Free Chlorine Residual	0.05 mg/L
Collection Time	11:30	Total Chlorine Residual	
Sampled By	Marc Maheux	Chlorinated?	Yes
Sampling Location	Kitchen Sink	Field Temp.	
Street Address	38 Poker Hill	Field Fluoride	
Town	Underhill	Temp at Receipt	

Test	Enzyme Substrate Test	Date/Time of Analysis	01/03/2014 10:30
		Test Method:	SM20 9223B

Analyte	Result
Total Coliform	Not detected
E.coli	Not detected

Units of Measurement and Definitions: mL = milliliter, > equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit,
TNTC = Too Numerous To Count

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti, Laboratory Director

*If you have received this report in error or have questions about this report,
please call the laboratory at (802) 863-7336.*