

VERMONT DEPARTMENT OF HEALTH LABORATORY
195 COLCHESTER AVENUE
BURLINGTON, VERMONT 05402-1125
(802) 863-7335 (800) 660-9997 (VT ONLY)

INORGANIC CHEMISTRY REPORT

LITS Number 2008000252-001-A

State Health Dept No. 08C1982

Kit Type Nitrate

WSID# 0000005096

Kit Number 9629339

Report To MARC MAHEUX

Address

38 POKER HILL RD

PO BX 236

UNDERHILL

VT 05489

Public Water System Only

JERICO-UNDERHILL WATER

Sampler Title OPERATOR

Purpose of Sample Compliance Monitor

Type of Sample Entry Point

CHLORINE, TOTAL (mg/L)

CHLORINE, FREE (mg/L)

Field Temp (C)

Date/Time Received 01/10/2008 12:43:00

Date/Time of Collection 01/10/2008 08:45:00

Town Underhill

Person Taking Sample MARC MAHEUX

Sample Location 52 RIVER RD - MOP SINK

Date Analyzed

Field Sample Number

Report Status Final

Date Reported 01/24/2008

Released by DLS

Anions	Result	Units	Method	Limits	
Total Nitrate & Nitrite*	< 0.5	mg/L	EPA 353.2	10. mg/L MCL (as Nitrogen)	

Comments:

Registry Comments:

Definitions: mg/L = milligrams per liter, or ppm (parts per million) < = less than

MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level VHA = Vermont Health Advisory

Action Level = level at or above which a water treatment action is determined for public water supplies

and should be considered for private supplies. * Total Nitrate and Nitrite = Nitrate-Nitrite, total measured as Nitrogen.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A 315 - 320). Results relate only to the items tested.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Page: 1 / 1

Date Printed: 01/24/2008 16:02:48

If you have questions about this report, please call the Laboratory at (802)863-7335.