

Laboratory Report



Jericho Underhill Water 100300
PO Box 174
Underhill, VT 05489
Atten: Andy Foresburg

PROJECT: WSID 5096 JerichoUnderhill TC
WORK ORDER: 2101-00341
DATE RECEIVED: January 06, 2021
DATE REPORTED: January 07, 2021
SAMPLER: Andy

VT0005096

001 Site: 45 Poker Hill Date Sampled: 1/5/21 Time: 19:00

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Free Chlorine Residual (Field Result):	0.04	ppm					
Total Coliform	Absent	/100 mL	SM20 9223B(04)	1/6/21 13:04	W AKJ	A	
E. coli	Absent	/100 mL	SM20 9223B(04)	1/6/21 13:04	W AKJ	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.
Laboratory Director

www.endynelabs.com



160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

56 Etna Road, Lebanon, NH 03766
Ph 603-678-4891 Fax 603-678-4893



WSID 5096

Total Coliform

Endyne Inc. COC

2101-00341

Bill to: Andy Foresburg, Jericho Underhill Water, PO Box 174, Underhill, VT 05489, Ph: 802-363-4586

Report to: Andy Foresburg, Jericho Underhill Water, PO Box 174, Underhill, VT 05489, jwater899@yahoo.com; kirk@cham...

Prepared: 8/12/20, Cust # 10, VT0005096, TC0005096



Jericho Underhill Water, WSID 5096 JerichoUnderhill TC

Was the water system chlorinated at the time of sample collection? Circle one: YES NO

Sampler:

Circle Sample Type for each sample: RT RP SP

1 Sterile 120 mL Bottle per Sample

A Foresburg

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: 0.04 mg/L

001 45 Poker Hill

Sampled Date/Time:

1/5/20 @ 1900

Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

002

Sampled Date/Time:

/ / @

Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

003

Sampled Date/Time:

/ / @

Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

004

Sampled Date/Time:

/ / @

Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

005

Sampled Date/Time:

/ / @

Chlorine, Total: mg/L

CHLORINATED

Relinquished by:

Jim Patch

1/6/21 7:10 AM

Accepted by:

Eileen Josmy 1/6/21 @ 7:08

Relinquished by:

Received by:

Sites/Parameters correct as listed. Client Initials

Date Time

Date Time

Client Authorization to use Subcontract lab Client Initials

Sample origin: VT NH NY Other

Special reporting instructions: (PO#)

Requested Turnaround Time: Routine: Rush Due Date

Delv: Client, Temp C: 9.6, Comment:

Tmpl Ck, Log by

Lab use Only



160 James Brown Dr. Williston, VT 05495, Ph 802-879-4333, Fax 802-879-7103

56 Etna Road, Lebanon, NH 03766, Ph 603-678-4891, Fax 603-678-4893

315 New York Rd. Plattsburgh, NY 12903, Ph 518-563-1720, Fax 518-563-0052