



VERMONT DEPARTMENT OF HEALTH LABORATORY

195 Colchester Ave., Burlington, VT 05402-1125

802-863-7335

800-660-9997

TEST RESULTS

MARC MAHEUX
32 POKER HILL RD
PO BX 236
UNDERHILL VT 05489

C0101570

Page 1 of 1

Inorganic Chemistry Analysis of Water

Laboratory Results of Analysis

Lab number..:	C0101570	WSID #:	5096
Kit Type...:	##	JERICHO-UNDERHILL WATER	
Received...:	03/08/01 1022	Collected:	03/08/01 0910
Sampler....:	MARC MAHEUX	Town of...:	UNDERHILL
Samp. Title:	Operator	Total Cl.:	
Purpose.....:	Compliance	Free Cl.:	
	Monitoring	Temp.....:	
Location...:	CONTROL		
	BUILDING		
Lab Comment:			
Sub. Remark:			

Test Category	Result	Limits	Units
Nitrate	< 0.5	10.0 MCL (as nitrogen)	mg/L

Definitions:

ppm = parts per million, milligrams per liter (mg/L), units in mg/L unless otherwise noted.
MCL = Maximum Contaminant Level
SMCL = Secondary Maximum Contaminant (Fluoride has a Secondary Maximum Contaminant Level of 2.0 mg/L)
TON = Threshold Odor Number
TDS = Total Dissolved Solids
≥ = Equal To or Greater Than

NTU = Nephelometric Turbidity Units
Langelier Index > 0 is considered non-corrosive, this is calculated umhos/cm = micromhos per centimeter
MBAS = Methylene Blue Active Substances
< = Less Than
> = Greater Than

This is a public record. Information contained in this record may be used for statistical purposes, and may be released upon request, pursuant to Vermont access to public documents law (1. V.S.A. §315-320.)

Results relate only to the items tested. This report shall not be reproduced, except in full, without the written approval of the Laboratory.

Date Reported: MAR 26 2001