



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # : 15-WB-05499
Report Status : Final
Date Report Released : 06/13/2016

Report To Jericho Underhill Water
ATTN OF Marc Maheux
Address PO Box 174

Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 06/10/2016
Time Received 09:41
Approved Date 06/13/2016

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	06/09/2016	Free Chlorine Residual	0.03 mg/L
Collection Time	13:30	Total Chlorine Residual	
Sampled By	Marc Maheux	Chlorinated?	Yes
Sampling Location	Kitchen sink	Field Temp.	
Street Address	60 Maple Ridge	Field Fluoride	
Town	Underhill	Temp at Receipt	
Sampler's Comments			

Test Enzyme Substrate Test

Date/Time of Analysis 06/11/2016 10:35
Test Method SM20 9223B

Analyte	Result
Total Coliform	Not detected
E.coli	Not detected

Units of Measurement and Definitions:

mL = milliliter, > equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit, TNTC = Too Numerous To Count

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti, Laboratory Director

If you have received this report in error or have questions about this report, please call the laboratory at (802) 338-4724.