



VERMONT

Agency of Human Services

Department of Health
Division of Health Improvement
Office of Oral Health
108 Cherry Street - PO Box 70
Burlington, VT 05402-0070
www.HealthyVermonters.info

[phone] 802-863-7341
[fax] 802-951-1218

May 18, 2006

Marc Maheux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Dear *Marc*
~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
03/03/06	1.2	1.0
03/10/06	1.1	1.0
03/17/06	1.1	0.9
03/24/06	1.2	0.9
03/31/06	1.1	0.9
04/07/06	1.2	0.9
04/14/06	1.1	0.8
04/21/06	1.0	0.8
04/28/06	1.0	0.8
05/05/06	1.0	0.7

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician