

VERMONT DEPARTMENT OF HEALTH LABORATORY
 195 COLCHESTER AVENUE
 BURLINGTON, VERMONT 05402-1125
 (802) 863-7335 (800) 660-9997 (VT ONLY)
 WATER BACTERIOLOGY RESULTS

LITS Number 2010000079-001-A

State Health Dept No.11WB01473

Kit Type Kit AA Coliform (Regulated Systems)

WSID# 0000005096

Kit Number 9663832

MARC

MAHEUX

Report To 38 POKER HILL RD
 PO BX 236
 UNDERHILL

VT 05489

Date/Time Received 08/18/2010 09:38:00

Date/Time of Collection 08/17/2010 18:00:00

Town Underhill

Collected By MARC MAHEUX

Date Analyzed 08/19/2010

Sample Location 52 River rd/sample tap(hydrant replacement)

Report Status Final

Field Sample Number

Date Reported 08/19/2010

Released by VLD

Public Water System Only

JERICO-UNDERHILL WATER

Sampler Title OPERATOR

Purpose of Sample Other

Type of Sample

Chlorine, free 0.29

Chlorine, total

Not chlorinated —

Field Temp (C)

Action Limit

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320) Results relate only to the items tested. This water was not analyzed for possible chemical contamination.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 08/19/2010 12:47:42