



Vermont Department of Health  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

March 21, 2002

*Marc Makeer*  
~~Helen Miller~~  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*Marc*  
Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
01/04/02	1.2	0.9
01/11/02	1.3	1.0
01/18/02	1.2	0.9
01/25/02	1.1	0.9
02/01/02	1.2	0.9
02/08/02	1.0	0.8
02/15/02	1.1	0.9


To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida I. Lund*

Alida I. Lund  
Fluoridation Technician



**Vermont Department of Health**  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

March 21, 2002

*Marc Mahieux*  
~~Helen Miller~~  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*Marc*  
Dear Mrs. Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
02/22/02	1.1	0.9
03/11/02	1.1	0.9

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida Lund*  
Alida I. Lund  
Fluoridation Technician