VERMONT DEPARTMENT OF HEALTH LABORATORY
195 COLCHESTER AVENUE
BURLINGTON, VERMONT 05402-1125
(802) 863-7335 (800) 660-9997 (VT ONLY)
WATER BACTERIOLOGY RESULTS

LITS Number 2008047162-001-A **State Health Dept No.** 10WB00233

Kit Type Kit AA Coliform (Regulated Systems) **WSID#** 0000005096

Kit Number 9645411

MARC MAHEUX

Report To
38 POKER HILL RD
PO BX 236
UNDERHILL VT 05489

Public Water System Only

JERICHO-UNDERHILL WATER

Sampler Title	OPERATOR
Purpose of Sample	Routine
Type of Sample	Distribution
Chlorine, free	0.24
Chlorine, total	
Field Temp (C)	
Action Limit	

Date/Time Received 07/07/2009 15:45:00

Date/Time of Collection 07/07/2009 11:00:00

Town Underhill

Collected By MARC MAHEUX

Sample Location 38 POKER HILL RD - KITCHEN SINK

Field Sample Number

Date Analyzed 07/08/2009

Report Status Final

Date Reported 07/08/2009

Released by BJC

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, persuant to Vermont Access to Public Documents law (1V.S.A.315-320)
Results relate only to the items tested. This water was not analyzed for possible chemical contamination.
This reports shall not be reproduced, except in full, without the written approval of the laboratory.
If you have questions about this report, please call the laboratory at (802)863-7335
Date Printed: 07/08/2009 12:17:22