

# Monthly Operations Report for Groundwater Systems and Systems Purchasing Water

Version 1.23, Record generated: 4/9/2024 1:35:05 PM

**Submission #:** HQ2-RPAQ-ZP1WG, version 1

## Details

---

**Submitted:** 4/9/2024 12:37:17 PM by Lane Simon

**ID:** VT0005096 March

**Submission ID:** HQ2-RPAQ-ZP1WG

## Form Input

---

### Water System Information

**Water System ID**

VT0005096

**Name of Water System**

JERICO UNDERHILL WATER

**Month Being Reported (the month the report represents, not the current month)**

March

**Report Year**

2024

**Any notes to share**

**Is a master meter which measures total water production of the system installed and functioning?**

Yes

**Meter Readings and Usage**

---

**Select how your usage is reported**

Gallons

**Meter reading on last day of previous month**

0

**Meter reading on last day of reporting month**

0

**Total Water Production for the Reporting Period**

1202911

Displayed below is your usage (in gallons) for the most recent period for which you submitted a report. This is provided for informational purposes only.

**Prior Report Total Water Production**

1137192

**Continuous Monitoring of Free Chlorine Residuals**

---

For systems with a population greater than 3300, continuous monitoring for free chlorine residuals is required. Those systems should also respond to the following questions:

**Did continuous monitoring fail at any time this month?**

No

**Are you submitting a daily detail table?**

Yes

**Daily Data Detail Table (1 of 1)**

---

**Facility**

TP001 - TREATMENT PLANT 1

**Did the facility utilize standby chlorination at any point during this reporting period**

Yes

**Are you reporting daily meter readings or daily gallons produced?**

Gallons produced

**Daily Reporting Data**

Day	Meter or Gallons	EP Cl Residual Daily Low (mg/L)	Fluoride (mg/L)	pH average	Phosphate Daily Low (mg/L)
03/01/2024	32922	0.625	0.9		0.91
03/02/2024	37183	0.625			
03/03/2024	36344	0.625	0.95		1.02
03/04/2024	34867	0.625			
03/05/2024	34686	0.625	0.96		0.98
03/06/2024	37062	0.625			
03/07/2024	37404	0.625			
03/08/2024	62906	0.625	0.95		0.89
03/09/2024	35879	0.625			
03/10/2024	35521	0.625			
03/11/2024	35065	0.625	0.91		0.8

03/12/2024	35986	0.625			
03/13/2024	37205	0.625	0.92		1.8
03/14/2024	35952	0.625			
03/15/2024	37405	0.163	0.95		1.73
03/16/2024	35478	-0.011			
03/17/2024	67614	0.124			
03/18/2024	36316	0.081	0.95		1.7
03/19/2024	34253	0.044			
03/20/2024	35942	0.002	0.91		1.4
03/21/2024	35117	0.148			
03/22/2024	37114	0.182			
03/23/2024	34541	0.151	0.89		1.28
03/24/2024	37466	0.176			
03/25/2024	36766	0.102	0.97		1.39
03/26/2024	64424	0.102			
03/27/2024	36703	0.066	0.99		1.34
03/28/2024	34450	0.075			
03/29/2024	35440	0.17	0.85		1.94
03/30/2024	36095	0.145			
03/31/2024	38805	0.136			