

VERMONT DEPARTMENT OF HEALTH LABORATORY
 195 COLCHESTER AVENUE
 BURLINGTON, VERMONT 05402-1125
 (802) 863-7335 (800) 660-9997 (VT ONLY)
 WATER BACTERIOLOGY RESULTS

LITS Number 2011018371-001-A State Health Dept No.12WB04268

Kit Type Kit AA Coliform (Regulated Systems) WSID# 0000005096

Kit Number

MARC MAHEUX
 JERICHO-UNDERHILL WATER

Report To PO BX 174
 UNDERHILL VT 05489

Date/Time Received 10/07/2011 09:03:00

Date/Time of Collection 10/06/2011 17:30:00

Town Jericho

Collected By MARC MAHEUX

Date Analyzed 10/08/2011 Sample Location united christian academy/raceway rd

Report Status Final Field Sample Number

Date Reported 10/10/2011

Released by SEF

Public Water System Only	
JERICHO-UNDERHILL WATER	
Sampler Title	
Purpose of Sample	Routine
Type of Sample	
Chlorine, free	0.02
Chlorine, total	
Not chlorinated	—
Field Temp (C)	
Action Limit	

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320)

Results relate only to the items tested. This water was not analyzed for chlorine residual.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 10/10/2011 12:33:59