



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

June 22, 2000

marc makey
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

marc
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
04/14/00	1.5	1.2
04/21/00	1.5	1.2
04/28/00	1.4	1.2
05/05/00	1.4	1.2
05/12/00	1.3	1.4
05/20/00	1.4	1.3

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician