

Results Report

State Health Dept # : 12-IC-03546

Report To JERICHO UNDERHILL WATER
ATTN OF MARC MAHEUX
Address PO BOX 174
 UNDERHILL, VT 05489

WSID VT0005096
Account Name JERICHO UNDERHILL WATER
Date Received 05/09/2013
Time Received 08:49
Approved Date 05/10/2013

Sample Desc. Munic FI
Collection Date 05/08/2013
Collection Time 06:02
Sampled By Helen Miller
Sampling Location
Street Address 406 VT Rte 15
Town Underhill

Sample Type
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride 1.2 mg/L
Temp at Receipt

<u>Test</u>	<u>Fluoride</u>	<u>Date/Time of Analysis</u>	05/09/2013 10:59
		Test Method:	LACHAT 10-109-12-2-A
Analyte	Final Result	Units	Limit
Fluoride	0.8	mg/L	4.0 MCL

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
 MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
 VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
 AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
 Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
 This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
 Access to Public Documents law (1 V.S.A. 315-320).
 This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By: 
 Mary Celotti, Laboratory Director

***If you have received this report in error or if you have questions about this report,
 please call the laboratory at (802) 863-7336.***