

LABORATORY REPORT

Jericho Underhill Water
PO Box 236
Underhill, VT 05489
Attn: Marc Maheux

PROJECT: WSID #5096
ORDER ID: 38487
RECEIVE DATE: July 15, 2005
REPORT DATE: July 28, 2005

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody. Different groups of analyses may be reported under separate cover.

All samples were prepared and analyzed by requirements outlined in the referenced methods and within the specified holding times.

All instrumentation was calibrated with the appropriate frequency and verified by the requirements outlined in the referenced methods.

Blank contamination was not observed at levels affecting the analytical results.

Analytical method precision and accuracy was monitored by laboratory control standards which include matrix spike, duplicate and quality control analyses. These standards were determined to be within established laboratory method acceptance limits, unless otherwise noted.

Reviewed by,

Harry B. Locker, Ph.D.
Laboratory Director

enclosures

LABORATORY REPORT

CLIENT: Jericho Underhill Water
PROJECT: WSID #5096
REPORT DATE: July 28, 2005

ORDER ID: 38487
DATE RECEIVED: July 15, 2005
SAMPLER: MM
ANALYST: 725

Ref. Number: 256086

Site: 32 Poker Hill Rd

Date Sampled: July 15, 2005

Time: 9:00 AM

<u>Parameter</u>	<u>Result</u>	<u>Unit</u>	<u>Method</u>	<u>Analysis Date</u>
Bromodichloromethane	1.1	ug/L	EPA 524.2-THM	7/23/05
Bromoform	< 0.5	ug/L	EPA 524.2-THM	7/23/05
Chloroform	2.2	ug/L	EPA 524.2-THM	7/23/05
Dibromochloromethane	0.6	ug/L	EPA 524.2-THM	7/23/05
Total Trihalomethanes	3.9	ug/L	EPA 524.2-THM	7/23/05
Surrogate 1	102.%	%	EPA 524.2-THM	7/23/05
Surrogate 2	99.%	%	EPA 524.2-THM	7/23/05
UIP's	> 10.		EPA 524.2-THM	7/23/05