

Monthly Operations Report for Groundwater Systems and Systems Purchasing Water

Version 1.25, Record generated: 7/8/2024 11:35:13 AM

Submission #: HQ4-ZBHN-310Q1, version 1

Details

Submitted: 7/8/2024 11:06:06 AM by Lane Simon

ID: VT0005096 2024 June

Submission ID: HQ4-ZBHN-310Q1

Form Input

Water System Information

Water System ID

VT0005096

Name of Water System

JERICO UNDERHILL WATER

Month Being Reported (the month the report represents, not the current month)

June

Report Year

2024

Any notes to share

Is a master meter which measures total water production of the system installed and functioning?

Yes

Meter Readings and Usage

Select how your usage is reported

Gallons

Meter reading on last day of previous month

0

Meter reading on last day of reporting month

0

Total Water Production for the Reporting Period

1367155

Displayed below is your usage (in gallons) for the most recent period for which you submitted a report. This is provided for informational purposes only.

Prior Report Total Water Production

1576162

Continuous Monitoring of Free Chlorine Residuals

For systems with a population greater than 3300, continuous monitoring for free chlorine residuals is required. Those systems should also respond to the following questions:

Did continuous monitoring fail at any time this month?

No

Are you submitting a daily detail table?

Yes

Daily Data Detail Table (1 of 1)

Facility

TP001 - TREATMENT PLANT 1

Did the facility utilize standby chlorination at any point during this reporting period

No

Are you reporting meter readings or gallons produced?

Meter readings

Daily Reporting Data

Day	Meter or Gallons	EP Cl Residual Daily Low (mg/L)	Fluoride (mg/L)	pH average	Phosphate Daily Low (mg/L)
06/01/2024	40665	0.017	0.94		
06/02/2024	71602	0.218	0.91		1.77
06/03/2024	40854	0.249	0.93		1.11
06/04/2024	71295	0.246			
06/05/2024	37981	0.237	0.64		0.74
06/06/2024	64459	0.328			
06/07/2024	39089	0.261	1.07		0.74
06/08/2024	36261	0.301			
06/09/2024	36519	0.273			
06/10/2024	37748	0.313	1.01		0.86
06/11/2024	38278	0.325			

06/12/2024	44794	0.301	0.96		0.66
06/13/2024	68091	0.402			
06/14/2024	38683	0.362	0.83		0.78
06/15/2024	41665	0.386			
06/16/2024	70619	0.368			
06/17/2024	43566	0.344	0.92		0.76
06/18/2024	41389	0.38			
06/19/2024	58428	0.353	0.41		0.68
06/20/2024	50636	0.313			
06/21/2024	37558	0.386	0.64		1.05
06/22/2024	35420	0.353			
06/23/2024	38493	0.386			
06/24/2024	35220	0.362	0.85		0.82
06/25/2024	34817	0.362			
06/26/2024	35473	0.377	0.89		1.32
06/27/2024	63947	0.417			
06/28/2024	36007	0.35	0.92		1.45
06/29/2024	35997	0.392			
06/30/2024	41601	0.402			