

## Results Report

State Health Dept # 19-IC-00928  
Report Status Final  
Date Report Released 06/11/2019

Report To Jericho Underhill Water  
ATTN of Marc Maheux  
Address PO Box 174  
Underhill, VT 05489

WSID VT0005096  
Account Name Jericho Underhill Water  
Date Received 06/07/2019  
Time Received 08:09  
Approved Date 06/11/2019

Sample Desc. Munic FI  
Collection Date 06/05/2019  
Collection Time 08:00  
Sampled By Helen Miller  
Sampling Location Kitchen Sink  
Street Address 406 Vt Rt 15  
Town Underhill

Sample Type Routine/Comp  
Collection Type N/A  
Free Chlorine Residual N/A  
Total Chlorine Residual N/A  
Chlorinated? N/A  
Field Temp. N/A  
Field Fluoride 1.1 mg/L  
Temp at Receipt N/A

### Test Anions

Date/Time of Analysis 06/07/2019 19:28  
Test Method EPA 300.0

| Analyte  | Final Result | Units | Limit   |
|----------|--------------|-------|---------|
| Fluoride | 0.65         | mg/L  | 4.0 MCL |

### Units of Measurement and Definitions:

N/A = Not Available; mg/L = Milligrams per liter or ppm (parts per million); ug/L = Micrograms per liter or ppb (parts per billion); < = less than; TON = Threshold Odor Number; MCL = Maximum Contaminant Level; SMCL = Secondary Maximum Contaminant Level; MRDL = Maximum Residual Disinfectant Level; VHA = Vermont Health Advisory; VMCL = Vermont Maximum Contaminant Level; NLE = No Limit Established; AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.


Unless otherwise noted all analyses performed under NELAP certification have complied with all the requirements for the TNI standard.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320). For guidance and treatment recommendations, please visit [www.healthvermont.gov/water-contaminants](http://www.healthvermont.gov/water-contaminants).

This report shall not be reproduced, except in full, without approval of the laboratory.

Test Report Authorized By:



Mary Celotti, Laboratory Director

If you have received this document in error or if you have questions about this report, please call 802-338-4724