

Results Report**State Health Dept #****19-WB-05326****Report Status****Final****Date Report Released****07/22/2019****Report To** Jericho Underhill Water
ATTN of Michael Willard
Address PO Box 174
Underhill, VT 05489**WSID** VT0005096
Account Name Jericho Underhill Water
Date Received 07/19/2019
Time Received 12:10**Sample Desc.** KIT AA
Collection Date 07/19/2019
Collection Time 09:15
Sampled By Michael Willard
Sampling Location Kitchen Sink
Street Address 37 River Rd
Town Jericho**State** VT**Sample Type** Other
Collection Type N/A
Free Chlorine Residual 0.35 mg/L
Total Chlorine Residual N/A
Chlorinated? Yes
Field Temp. N/A
Field Fluoride N/A
Temp at Receipt N/A**Sampler's Comments**

To confirm no bactie after valve replacement.

Test **Enzyme Substrate Test****Date/Time of Analysis** 07/20/2019 10:43**Test Method** SM20 9223B

Analyte	Result
Total Coliform	Detected
E.coli	Not detected

Units of Measurement and Definitions: N/A = Not Available; mL = milliliter; ">" = greater than; "<" = less than; MPN = Most Probable Number; CFU = Colony Forming Unit; TNTC = Too Numerous To Count

Unless otherwise noted all analyses performed under NELAP certification have complied with all the requirements for the TNI standard.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320). For guidance and treatment recommendations, please visit

www.healthvermont.gov/water-contaminants.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti, Laboratory Director

If you have received this document in error or if you have questions about this report, please call 802-338-4724