



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # 19-WB-05339
Report Status Final
Date Report Released 07/26/2019

Report To Jericho Underhill Water
ATTN of Michael Willard
Address PO Box 174
Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 07/25/2019
Time Received 14:38

Sample Desc. KIT AA
Collection Date 07/24/2019
Collection Time 17:45
Sampled By Michael Willard
Sampling Location entry point
Street Address 52 River Rd
Town Underhill State VT
Sample Type Repeat
Collection Type N/A
Free Chlorine Residual 0.51 mg/L
Total Chlorine Residual N/A
Chlorinated? Yes
Field Temp. N/A
Field Fluoride N/A
Temp at Receipt N/A

Sampler's Comments
Repeat sample RS(B)-1

Test Enzyme Substrate Test
Date/Time of Analysis 07/26/2019 11:02
Test Method SM20 9223B

Analyte Result
Total Coliform Not detected
E.coli Not detected

Units of Measurement and Definitions: N/A = Not Available; mL = milliliter; ">" = greater than; "<" = less than; MPN = Most Probable Number; CFU = Colony Forming Unit; TNTC = Too Numerous To Count

Unless otherwise noted all analyses performed under NELAP certification have complied with all the requirements for the TNI standard.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320). For guidance and treatment recommendations, please visit

www.healthvermont.gov/water-contaminants.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti

Mary Celotti, Laboratory Director

If you have received this document in error or if you have questions about this report, please call 802-338-4724