



Vermont Department of Health  
Division of Health Improvement  
Dental Health Services

Agency of Human Services

August 7, 2002

*marc mahaux*  
~~Heien Miller~~  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*marc*  
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
06/14/02	1.2	0.9
06/21/02	1.3	1.2
06/28/02	1.2	1.2
07/05/02	1.3	1.2
07/12/02	1.2	1.2
07/19/02	1.3	1.2
07/26/02	1.2	1.1

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida Lund*  
Alida I. Lund  
Fluoridation Technician