



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

February 3, 2005

Marc Mahceux

~~Helen Miller~~

Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Marc
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
12/17/04	1.2	1.0
12/24/04	1.2	1.0
12/31/04	1.0	0.9
01/07/05	1.0	0.9
01/14/05	1.0	0.9
01/21/05	1.1	0.9

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund
Fluoridation Technician