**VERMONT DEPARTMENT OF HEALTH LABORATORY**
**195 COLCHESTER AVENUE**
**BURLINGTON, VERMONT 05402-1125**
**(802) 863-7335 (800) 660-9997 (VT ONLY)**
**WATER BACTERIOLOGY RESULTS**

**LITS Number** 2011013987-001-A **State Health Dept No.** 12WB01410

**Kit Type** Kit AA Coliform (Regulated Systems) **WSID#** 0000005096

**Kit Number**

Report To
MARC MAHEUX
JERICHO-UNDERHILL WATER
PO BOX 174
UNDERHILL VT 05489

**Public Water System Only**

| | |
|---|---|
| **JERICHO-UNDERHILL WATER** | |
| **Sampler Title** | |
| **Purpose of Sample** | Routine |
| **Type of Sample** | |
| **Chlorine, free** | 0.11 |
| **Chlorine, total** | |
| **Not chlorinated** | — |
| **Field Temp (C)** | |
| **Action Limit** | Presence |

**Date/Time Received** 08/03/2011 10:39:00
**Date/Time of Collection** 08/03/2011 09:45:00

**Town** Underhill

**Collected By** Marc Maheux
**Date Analyzed** 08/04/2011
**Sample Location** 7 Park St/Kitchen Sink
**Report Status** Final
**Field Sample Number**
**Date Reported** 08/04/2011
**Released by** SEF

| Test | Code | Result Description |
|---|---|---|
| MMO-MUG | 00 | Total coliform not detected, E. coli not detected |

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, persuant to Vermont Access to Public Documents law (1V.S.A.315-320)
Results relate only to the items tested. This water was not analyzed for chlorine residual.
This report shall not be reproduced, except in full, without the written approval of the laboratory.
If you have questions about this report, please call the laboratory at (802)863-7335
Date Printed: 08/04/2011 14:17:28