

VERMONT DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE

BURLINGTON, VERMONT 05402-1125

(802) 863-7335 (800) 660-9997 (VT ONLY)

WATER BACTERIOLOGY RESULTS

LITS Number 2008047164-001-A

State Health Dept No.10WB03424

Kit Type Kit AA Coliform (Regulated Systems)

WSID# 0000005096

Kit Number 9645413

Report To  
 MARC MAHEUX  
 JERICO-UNDERHILL WATER  
 38 POKER HILL RD  
 PO BX 236  
 UNDERHILL VT 05489

Public Water System Only

JERICO-UNDERHILL WATER

Sampler Title OPERATOR  
 Purpose of Sample Routine  
 Type of Sample Distribution  
 Chlorine, free 0.19  
 Chlorine, total  
 Field Temp (C)  
 Action Limit

Date/Time Received 10/05/2009 11:18:00

Date/Time of Collection 10/05/2009 10:30:00

Town Jericho

Collected By MARC MAHEUX

Sample Location 100 RACEWAY KITCHEN SINK

Date Analyzed 10/06/2009

Field Sample Number

Report Status Final

Date Reported 10/06/2009

Released by CEL

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320) Results relate only to the items tested. This water was not analyzed for possible chemical contamination.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 10/06/2009 11:00:19