



**Vermont Department of Health**  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

September 24, 2001

*Marc Mahoney*  
Helen Miller  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*Marc*  
Dear Mrs. Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
08/03/01	1.0	0.9
08/10/01	1.1	1.1
08/17/01	1.3	1.0
08/24/01	1.1	1.0
08/31/01	1.2	1.0
09/07/01	1.2	1.0
09/14/01	1.2	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida Lund*

Alida I. Lund  
Fluoridation Technician