



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

April 30, 2001

Marc Mayheux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Dear ~~Mrs. Miller~~ *Marc*:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
03/02/01	1.2	1.2
03/09/01	1.3	1.1
03/16/01	1.2	1.0
03/23/01	1.1	1.0
04/06/01	1.2	0.9
04/13/01	1.2	0.8

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund
Alida I. Lund
Fluoridation Technician