

Monthly Operations Report for Groundwater Systems and Systems Purchasing Water

Version 1.31, Record generated: 3/6/2026 2:35:11 PM

Submission #: HQK-VM15-5RD4P, version 1

Details

Submitted: 3/6/2026 1:32:48 PM by Lane Simon

ID: VT0005096 2026 February

Submission ID: HQK-VM15-5RD4P

Form Input

Water System Information

Water System ID

VT0005096

Name of Water System

JERICO UNDERHILL WATER

Report Year

2026

Month Being Reported (the month the report represents, not the current month)

February

Any notes to share

Is a master meter which measures total water production of the system installed and functioning?

Yes

Meter Readings and Usage

Select how your usage is reported

Gallons

Meter reading on last day of previous month

0

Meter reading on last day of reporting month

0

Total Water Production for the Reporting Period

1033345

Displayed below is your usage (in gallons) for the most recent period for which you submitted a report. This is provided for informational purposes only.

Prior Report Total Water Production

1176090

Continuous Monitoring of Free Chlorine Residuals

For systems with a population greater than 3300, continuous monitoring for free chlorine residuals is required. Those systems should also respond to the following questions:

Did continuous monitoring fail at any time this month?

No

Are you submitting a daily detail table?

Yes

Daily Data Detail Table (1 of 1)

Facility

TP001 - TREATMENT PLANT 1

Did the facility utilize standby chlorination at any point during this reporting period

Yes

Are you writing down the numbers from the meter display or are you calculating the amount of water produced each day?

Recording the meter each day

Does the meter report in gallons or cubic feet?

Gallons

Daily Reporting Data

Day	Meter or Gallons	EP Cl Residual Daily Low (mg/L)	Fluoride (mg/L)	pH average	Phosphate Daily Low (mg/L)
02/01/2026	29187	0.942			
02/02/2026	47441	0.524	0.66		1.66
02/03/2026	26777	0.606			
02/04/2026	47378	0.881	0.9		1.25
02/05/2026	28788	0.579			
02/06/2026	44794	2.442	0.87		0.83
02/07/2026	27517	0.499			
02/08/2026	48955	0.402			

02/09/2026	51478	0.435	0.88		0.8
02/10/2026	24382	0.53			
02/11/2026	50999	2.442	0.46		1.05
02/12/2026	24802	0.041			
02/13/2026	48429	0.631	0.66		0.92
02/14/2026	24110	0.505			
02/15/2026	51229	0.603			
02/16/2026	27728	2.442	0.66		0.91
02/17/2026	29833	0.386			
02/18/2026	53035	0.667	0.8		1.07
02/19/2026	27339	0.484	0.7		1
02/20/2026	50271	0.741			
02/21/2026	24640	0.46			
02/22/2026	47651	0.802			
02/23/2026	23591	0.722	0.73		0.6
02/24/2026	24914	0.591			
02/25/2026	46076	0.493	0.65		1.2
02/26/2026	27957	0.554			
02/27/2026	24280	2.442	0.68		0.87
02/28/2026	49764	2.442			