



Vermont Department of Health  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

June 14, 2001

*Marc Mayheux*  
~~Helen Miller~~  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*Marc Mayheux*  
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
04/20/01	1.0	0.8
04/27/01	1.1	0.9
05/04/01	1.2	0.9
05/11/01	1.2	0.7
05/18/01	0.8	0.6
05/25/01	0.9	0.7
06/01/01	0.8	0.5
06/08/01	1.3	1.1
Missing date	Missing data	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida I. Lund*

Alida I. Lund  
Fluoridation Technician