



Vermont Department of Health  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

January 27, 2004

*Marc Maheux*  
~~Helen Miller~~  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*Marc*  
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
12/05/03	1.0	1.1
12/12/03	1.1	1.1
12/19/03	1.1	1.1
12/26/03	1.2	1.1
01/02/04	1.2	1.0
01/09/04	1.1	0.8
01/16/04	1.0	0.7

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida I. Lund*  
Alida I. Lund  
Fluoridation Technician