

VERMONT DEPARTMENT OF HEALTH LABORATORY
195 COLCHESTER AVENUE
BURLINGTON, VERMONT 05402-1125
(802) 863-7335 (800) 660-9997 (VT ONLY)
WATER BACTERIOLOGY RESULTS

LITS Number 2009013569-001-A State Health Dept No.09WB08206

Kit Type Kit AA Coliform (Regulated Systems) WSID# 0000005096

Kit Number 9645410

Report To MARC MAHEUX
JERICO-UNDERHILL WATER
38 POKER HILL RD
PO BX 236
UNDERHILL VT 05489

Public Water System Only

JERICO-UNDERHILL WATER

Sampler Title OPERATOR
Purpose of Sample Routine
Type of Sample Distribution
Chlorine, free 0.2
Chlorine, total
Field Temp (C)
Action Limit Presence

Date/Time Received 04/06/2009 10:54:00

Date/Time of Collection 04/06/2009 10:05:00

Town Jericho Collected By MARC MAHEUX
Sample Location 8 RIVER RD BAR SINK

Date Analyzed 04/07/2009 Field Sample Number

Report Status Final

Date Reported 04/07/2009

Released by VLC

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320) Results relate only to the items tested. This water was not analyzed for possible chemical contamination.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 04/07/2009 11:35:28