



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # : 16-IC-04717
Report Status : Final
Date Report Released : 07/03/2017

Report To Jericho Underhill Water
ATTN OF Marc Maheux
Address PO Box 174

Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 06/22/2017
Time Received 08:22
Approved Date 07/03/2017

Sample Desc.	Munic FI	Sample Type	Routine/Comp
Collection Date	06/21/2017	Free Chlorine Residual	
Collection Time	08:30	Total Chlorine Residual	
Sampled By	Helen Miller	Chlorinated?	
Sampling Location	Kitchen Sink	Field Temp.	
Street Address	406 Vt Rt 15	Field Fluoride	0.9 mg/L
Town	Underhill	Temp at Receipt	
Sampler's Comments			

Test	Fluoride	Date/Time of Analysis	06/27/2017 13:42
		Test Method	LACHAT 10-109-12-2-A

Analyte	Final Result	Units	Limit
Fluoride	0.7	mg/L	4.0 MCL

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report, please call the laboratory at (802) 338-4724