



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # : 18-WB-04227
Report Status : Final
Date Report Released : 10/18/2018

Report To Jericho Underhill Water
ATTN OF Marc Maheux
Address PO Box 174

Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 10/17/2018
Time Received 13:43
Approved Date 10/18/2018

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	10/17/2018	Free Chlorine Residual	
Collection Time	12:08	Total Chlorine Residual	0.00 mg/L
Sampled By	Marc Maheux	Chlorinated?	Yes
Sampling Location	Kitchen Sink	Field Temp.	
Street Address	100 Raceway	Field Fluoride	
Town	Jericho	Temp at Receipt	
Sampler's Comments			

Test	Enzyme Substrate Test	Date/Time of Analysis	10/18/2018 11:24
		Test Method	SM20 9223B
Analyte		Result	
Total Coliform		Not detected	
E.coli		Not detected	

Units of Measurement and Definitions:

mL = milliliter, > equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit, TNTC = Too Numerous To Count

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti, Laboratory Director

If you have received this report in error or have questions about this report, please call the laboratory at (802) 338-4724.