

Results Report

State Health Dept # : 14-WB-07868

Report To Jericho Underhill Water
ATTN OF Marc Maheux
Address PO Box 174

Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 05/05/2015
Time Received 15:54
Approved Date 05/06/2015

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	05/05/2015	Free Chlorine Residual	
Collection Time	10:45	Total Chlorine Residual	
Sampled By	Marc Maheux	Chlorinated?	Yes
Sampling Location	Kitchen Sink	Field Temp.	
Street Address	38 Poker Hill	Field Fluoride	
Town	Underhill	Temp at Receipt	

Test Enzyme Substrate Test

Date/Time of Analysis 05/06/2015 11:15
Test Method: SM20 9223B

Analyte	Result
Total Coliform	Not detected
E.coli	Not detected

Units of Measurement and Definitions: mL = milliliter, > equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit, TNTC = Too Numerous To Count

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.


Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:



Mary Celotti, Laboratory Director

***If you have received this report in error or have questions about this report,
please call the laboratory at (802) 863-7336.***