



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

June 28, 2004

Mare Mahew
~~Helen Miller~~

Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Mare
Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
03/19/04	0.9	0.6
03/26/04	0.8	0.5
04/02/04	0.7	0.5
04/09/04	0.7	0.4
04/15/04	0.7	0.3
04/23/04	0.8	0.3
04/30/04	0.7	1.0
05/07/04	0.6	0.3
05/14/04	0.6	0.2
05/29/04	1.0	0.9
06/04/04	1.1	1.0
06/11/04	1.0	0.9

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund

Alida I. Lund
Fluoridation Technician