

# Monthly Operations Report for Groundwater Systems and Systems Purchasing Water

Version 1.30, Record generated: 10/8/2021 12:00:11 PM

**Submission #:** HPC-AD51-B5VKT, version 1

## Details

---

**Submitted:** 10/8/2021 10:43:32 AM by Kirk Patch

**ID:** VT0005096 September

**Submission ID:** HPC-AD51-B5VKT

## Form Input

---

### Water System Information

**Water System ID**

VT0005096

**Name of Water System**

JERICO UNDERHILL WATER

**Month Being Reported**

September

**Report Year**

2021

**Any notes to share**

**Is a master meter which measures total water production of the system installed and functioning?**

Yes

Meter Readings and Usage

---

**Select how your usage is reported**

Gallons

**Meter reading on last day of previous month**

**Meter reading on last day of reporting month**

**Total Water Production for the Reporting Period**

1395500

Displayed below is your usage (in gallons) for the most recent period for which you submitted a

report. This is provided for informational purposes only.

**Prior Report Total Water Production**

1408500

**Continuous Monitoring of Free Chlorine Residuals**

---

For systems with a population greater than 3300, continuous monitoring for free chlorine residuals is required. Those systems should also respond to the following questions:

**Did continuous monitoring fail at any time this month?**

**Are you submitting a daily detail table?**

Yes

**Daily Data Detail Table (1 of 1)**

---

**Facility**

TP001 - TREATMENT PLANT 1

**Did the facility utilize standby chlorination at any point during this reporting period**

Yes

**Daily Reporting Data**

Day	Meter	EP Cl Residual Daily Low (mg/L)	Fluoride (mg/L)	pH average	Phosphate Daily Low (mg/L)
09/01/2021	70700	0.18	0.6		2.75
09/02/2021	40700	0.17	0.7		2.75
09/03/2021	43300	0.16	0.7		2.75
09/04/2021	42200	0.16	0.7		2.75
09/05/2021	43000	0.15	0.7		2.75
09/06/2021	71100	0.17			2.15
09/07/2021	40900	0.15	0.8		2.15
09/08/2021	40100	0.17	0.7		1.82
09/09/2021	37000	0.15	0.9		1.82
09/10/2021	66100	0.16	0.8		1.91
09/11/2021	54900	0.16	0.8		1.91
09/12/2021	41400	0.16	0.8		1.91
09/13/2021	46300	0.15			1.93
09/14/2021	38700	0.12	0.7		1.93
09/15/2021	77200	0.15	0.8		1.47
09/16/2021	43700	0.13	0.7		1.47

09/17/2021	39600	0.15	0.7		1.51
09/18/2021	41200	0.14	0.7		1.51
09/19/2021	39600	0.12	0.7		1.51
09/20/2021	41500	0.15			1.65
09/21/2021	37800	0.14	0.8		1.65
09/22/2021	72700	0.15	0.8		1.48
09/23/2021	42100	0.15	0.8		1.48
09/24/2021	39000	0.13	0.7		1.48
09/25/2021	47200	0.15	0.6		1.48
09/26/2021	38500	0.12	0.5		1.48
09/27/2021	43000	0.12			1.65
09/28/2021	39000	0.14	0.6		1.65
09/29/2021	38500	0.11	0.6		1.65
09/30/2021	38500	0.14	0.7		1.65