



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

August 1, 2000

Marc Mayhew
~~Helen Miller~~

Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Marc
Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
05/26/00	1.2	1.3
06/02/00	1.3	1.3
06/09/00	1.3	1.3
06/16/00	1.4	1.3
06/23/00	1.3	1.3
06/30/00	1.3	1.3
07/07/00	1.4	1.3
07/14/00	1.4	1.3
07/21/00	1.3	1.3

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund
Fluoridation Technician