

VERMONT DEPARTMENT OF HEALTH LABORATORY
 195 COLCHESTER AVENUE
 BURLINGTON, VERMONT 05402-1125
 (802) 863-7335 (800) 660-9997 (VT ONLY)
 WATER BACTERIOLOGY RESULTS

LITS Number 2008047163-001-A State Health Dept No.10WB02470

Kit Type Kit AA Coliform (Regulated Systems) WSID# 0000005096
 Kit Number 9645412

Report To MARC MAHEUX
 JERICHO-UNDERHILL WATER
 38 POKER HILL RD
 PO BX 236
 UNDERHILL VT 05489

Public Water System Only	
JERICHO-UNDERHILL WATER	
Sampler Title	OPERATOR
Purpose of Sample	Routine
Type of Sample	Distribution
Chlorine, free	0.16
Chlorine, total	
Field Temp (C)	
Action Limit	

Date/Time Received 09/03/2009 09:32:00
 Date/Time of Collection 09/03/2009 08:30:00

Town Underhill Collected By MARC MAHEUX
 Sample Location 38 POKER HILL KITCHEN
 Date Analyzed 09/04/2009 Field Sample Number
 Report Status Final
 Date Reported 09/04/2009
 Released by SEF

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320) Results relate only to the items tested. This water was not analyzed for possible chemical contamination.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 09/04/2009 13:15:28