



**MONTHLY OPERATIONS REPORT FOR GROUNDWATER SYSTEMS AND SYSTEMS PURCHASING WATER**

For the Month of Oct-22 WSID# 5096  
 Name of Water System: Jericho Underhill Water

Minimum free chlorine residual required for 4 Log viral inactivation (mg/l):

Day of Month	Water Production Metered Values (Gallons/Day)	Disinfection/Chlorination (Free CL, in mg/l)		Fluoride (mg/L) Entry Point	PO4 Entry Point
		Entry Point Daily Low	Distribution System (When taking coliform sample)		
1	38,241	0.01			
2	40,535	0.02			
3	39,710	0.00			0.61
4	69,322	0.21			
5	36,747	0.29			1.43
6	41,110	0.29			
7	36,904	0.07			0.43
8	40,278	0.38			
9	39,293	0.42			
10	38,302	0.32			0.81
11	63,885	0.32			
12	40,846	0.40			0.84
13	39,716	0.40			
14	37,945	0.37			0.77
15	41,508	0.06			
16	64,505	0.00			
17	45,008	0.04			2.75
18	36,267	0.07			
19	36,530	0.08			1.04
20	38,406	0.11			
21	37,374	0.09			1.02
22	65,627	0.14			
23	38,689	0.14			
24	36,440	0.16			0.84
25	39,217	0.16			
26	48,372	0.14			2.75
27	57,454	0.17			
28	36,391	0.15			1.26
29	36,943	0.13			
30	39,612	0.13			
31	37,794	0.12			1.06
<b>Totals</b>	<b>1,338,971</b>				

Note: Daily low for systems with continuous monitoring. Others - during the hour of peak flow.