

VERMONT DEPARTMENT OF HEALTH LABORATORY  
195 COLCHESTER AVENUE  
BURLINGTON, VERMONT 05402-1125  
(802) 863-7335 (800) 660-9997 (VT ONLY)  
WATER BACTERIOLOGY RESULTS

LITS Number 2006051753-001-A State Health Dept No.07WB05813

Kit Type Kit AA Coliform (Regulated Systems) WSID# 0000005096

Kit Number 9608694

MARC MAHEUX

Report To 32 POKER HILL RD  
PO BX 236  
UNDERHILL VT 05489

Public Water System Only

JERICO-UNDERHILL WATER

Sampler Title OPERATOR  
Purpose of Sample Routine  
Type of Sample  
Chlorine, free 0.02  
Chlorine, total  
Field Temp (C)  
Action Limit

Date/Time Received 12/05/2006 13:35:00

Date/Time of Collection 12/05/2006 09:20:00

Town Underhill

Collected By M MAHEUX

Sample Location 38 POKER HILL RD

Date Analyzed 12/06/2006

Field Sample Number

Report Status Final

Date Reported 12/06/2006

Released by SEF

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

The water sample tested is bacteriologically suitable for drinking (potable). IMPORTANT: Bacteriological testing of a single sample of water is only one means of determining the suitability of water for drinking. It is also critical that the water source location, system construction and ongoing maintenance/treatment are adequate to consistently protect against bacterial contamination.

**METHOD: SM9223**

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320) Results relate only to the items tested. This water was not analyzed for possible chemical contamination.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 12/06/2006 11:43:45