



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 19-IC-00283
Report Status: Final
Date Report Released: 02/22/2019

Report To: Jericho Underhill Water
ATTN OF: Marc Maheux
Address: PO Box 174
Underhill, VT 05489

WSID: VT0005096
Account Name: Jericho Underhill Water
Date Received: 02/20/2019
Time Received: 09:55
Approved Date: 02/22/2019

Table with 4 columns: Sample Desc., Collection Date, Collection Time, Sampled By, Sampling Location, Street Address, Town, Sampler's Comments, Sample Type, Collection Type, Free Chlorine Residual, Total Chlorine Residual, Chlorinated?, Field Temp., Field Fluoride, Temp at Receipt.

Test: Anions
Date/Time of Analysis: 02/20/2019 19:22
Test Method: EPA 300.0

Table with 4 columns: Analyte, Final Result, Units, Limit. Row: Nitrate as N, <0.50, mg/L, 10.0 MCL.

** See below for Nitrate and/or Nitrite.

** Note: The sample, upon receipt, was warmer than the test method suggests. There was evidence that the sample was being cooled from the time of sample collection to receipt by the laboratory.

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By: Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report, please call the laboratory at (802) 338-4724