



**Vermont Department of Health**  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

June 4, 2003

*Marc Mahoney*  
~~Helen Miller~~

Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*Marc*  
Dear Mrs. ~~Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
03/28/03	1.1	1.0
04/04/03	1.1	1.0
04/11/03	1.3	1.0
04/18/03	1.2	1.1
05/16/03	1.3	1.0
05/23/03	1.4	1.0
05/02/03	<i>missing data</i>	1.0
05/04/03	1.2	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida Lund*

Alida I. Lund  
Fluoridation Technician