


Laboratory Report**ENDYNE Inc.**
Environmental Laboratories

Jericho Underhill Water 100300
P.O. Box 174
Underhill, VT 05489
Atten: Nancy Benson

PROJECT: WSID 5096 TC

WORK ORDER: 2512-43851

DATE RECEIVED: December 23, 2025

DATE REPORTED: December 24, 2025

SAMPLER: Ryan Cotnoir

VT0005096

001 Site: 419 Rt 15

Date Sampled: 12/23/25 Time: 11:00

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

Free Chlorine Residual (Field Result): 0.43 ppm

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Total Coliform	ABSENT	/100 mL	SM23 9223B(04)	12/23/25 15:58	W KMB	A	
E. coli	ABSENT	/100 mL	SM23 9223B(04)	12/23/25 15:58	W KMB	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.
Laboratory Director

www.endynelabs.com

160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

ELAP 11263

56 Etna Road, Lebanon, NH 03766
Ph 603-678-4891 Fax 603-678-4893



NH2037

WSID 5096

Total Coliform
Endyne Inc. COC

2512-43851

Bill to:

Nancy Benson
Jericho Underhill Water
P.O. Box 174
Underhill VT 05489
Ph: 802-899-3017

Report to:

Nancy Benson
Jericho Underhill Water
P.O. Box 174
Underhill VT 05489
mmaheux@juwater.org; clerk@juwa

Prepared: 7/15/25

Cust # 1003

VT0005096

TC0005096

Jericho Underhill Water
WSID 5896 TC

of 1

Was the water system chlorinated at the time of sample collection? Circle one: YES NO

Sampler:

Circle Sample Type for each sample: RT RP SP

1 Sterile 120 mL Bottle per Sample

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: 43 mg/L

001 9/19 RT 15 Sampled Date/Time: 12/23/25 @ 11:00 am pm Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

002 Sampled Date/Time: / / @ am pm Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

003 Sampled Date/Time: / / @ am pm Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

004 Sampled Date/Time: / / @ am pm Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L

005 Sampled Date/Time: / / @ am pm Chlorine, Total: mg/L

Fac.ID: WL00_ Smp Pt: RW00_ Ctg: TC Smp Typ: TG Repl: Y/N Cmpl Ind: Y/N

Source Sampled Date/Time: / / @ am pm

CHLORINATED

Relinquished by: Ryan Cotnoir 12/23/25 Accepted by:

Relinquished by: Date Time Received by: 12-23-25 1:24 pm Date Time

Sites/Parameters correct as listed. Client Initials

Client Authorization to use Subcontract lab Client Initials

Sample origin: VT ☐ NH ☐ NY ☐ Other ☐

Special reporting instructions: (PO#)

Requested Turnaround Time: Routine: Rush Due Date

Delv: client
Temp C: 0.0
Comment:

One or more sample bottles in this project must be kept refrigerated or on ice until delivery at the laboratory.

Initial here allow Endyne to proceed with analysis if the temperature preservation requirements are not satisfied. Initial

Samples were received in the lab on ice. Y/N

160 James Brown Dr.
Williston, VT 05495
Ph 802-879-433356 Etna Road
Lebanon, NH 03766
Ph 603-678-4891315 New York Rd.
Plattsburgh, NY 12903
Ph 518-563-1720