



**Vermont Department of Health**  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

October 30, 2000

*marc makeux*  
Helen Miller  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*marc*  
Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
07/28/00	1.4	1.4
08/04/00	1.3	1.3
08/11/00	1.4	1.3
08/18/00	1.3	1.2
08/25/00	1.3	1.2
09/01/00	1.4	1.3
09/06/00	1.6	1.3
09/08/00	1.4	1.3
09/15/00	1.1	0.9
09/22/00	1.2	1.0
09/29/00	1.0	0.9

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida I. Lund*

Alida I. Lund  
Fluoridation Technician