

**Laboratory Report**



Jericho Underhill Water 100300  
PO Box 174  
Underhill, VT 05489  
Atten: Michael Willard

PROJECT: WSID 5096 JerichoUnderhill TC  
WORK ORDER: 2005-09619  
DATE RECEIVED: May 04, 2020  
DATE REPORTED: May 05, 2020  
SAMPLER: Marc

**VT0005096**

001 Site: 38 Poker Hill Date Sampled: 5/3/20 Time: 8:15

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Free Chlorine Residual (Field Result):	0.10	ppm					
Total Coliform	Absent	/100 mL	SM20 9223B(04)	5/4/20 13:47	W KMB	A	
E. coli	Absent	/100 mL	SM20 9223B(04)	5/4/20 13:47	W KMB	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.  
Laboratory Director

[www.endynelabs.com](http://www.endynelabs.com)



160 James Brown Dr., Williston, VT 05495  
Ph 802-879-4333 Fax 802-879-7103

56 Etna Road, Lebanon, NH 03766  
Ph 603-678-4891 Fax 603-678-4893



WSID 5096 Jericho Underhill

Total Coliform

Endyne Inc. COC

2005-09619

Bill to: Sara Martin  
Champlin Associates, Inc  
6 Pinecrest Drive  
Essex Jct. VT 05452  
Ph: 802-879-7136

Report to: Dave Crawford  
Champlin Associates, Inc  
6 Pinecrest Drive  
Essex Jct. VT 05452  
kirk@champlinassociates.com

Prepared: 4/20/20  
Cust # 10121  
VT0005096  
TC0005096



Jericho Underhill Water  
WSID 5096 JerichoUnderhill TC

Was the water system chlorinated at the time of sample collection? Circle one: YES NO

Sampler: Marc

Circle Sample Type for each sample RT RP SP 1 Sterile 120 mL Bottle per Sample

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: 0.10 mg/L  
001 38 Pokes Hill Sampled Date/Time: 5/3/20 @ 8:15 Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L  
002 Sampled Date/Time: @ Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L  
003 Sampled Date/Time: @ Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L  
004 Sampled Date/Time: @ Chlorine, Total: mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: mg/L  
005 Sampled Date/Time: @ Chlorine, Total: mg/L

# CHLORINATED

Relinquished by: Jim Poteh 5/4/20 7:15am Accepted by: Alice Tomay 5/4/20 @ 7:20  
Date Time Date Time

Relinquished by: Received by: Date Time Date Time

Sites/Parameters correct as listed. Client Initials KP Date Time Date Time

Client Authorization to use Subcontract lab Client Initials KP

Sample origin: VT  NH  NY  Other   
Special reporting instructions: (PO#)

Requested Turnaround Time: Routine: Rush Due Date

Delv: Client	Temp C: 13.4	Comment:	Tmpl Ck	Lab use Only
			Log by	



160 James Brown Dr.  
Williston, VT 05495  
Ph 802-879-4333  
Fax 802-879-7103

56 Etna Road  
Lebanon, NH 03766  
Ph 603-678-4891  
Fax 603-678-4893

315 New York Rd.  
Plattsburgh, NY 12903  
Ph 518-563-1720  
Fax 518-563-0052