

Results Report
State Health Dept # 19-WB-05335
Report Status Final
Date Report Released 07/26/2019

Report To Jericho Underhill Water
ATTN of Michael Willard
Address PO Box 174
Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 07/25/2019
Time Received 14:38

Sample Desc.	KIT AA	Sample Type	Special
Collection Date	07/25/2019	Collection Type	N/A
Collection Time	11:55	Free Chlorine Residual	0.41 mg/L
Sampled By	Michael Willard	Total Chlorine Residual	N/A
Sampling Location	bathroom sink	Chlorinated?	Yes
Street Address	406 Rt 15	Field Temp.	N/A
Town	Underhill	Field Fluoride	N/A
	State VT	Temp at Receipt	N/A

Sampler's Comments

check distribution system away from repair SP-001

Test *Enzyme Substrate Test* **Date/Time of Analysis** 07/26/2019 11:02
Test Method SM20 9223B

Analyte	Result
Total Coliform	Not detected
E.coli	Not detected

Units of Measurement and Definitions: N/A = Not Available; mL = milliliter; ">" = greater than; "<" = less than; MPN = Most Probable Number; CFU = Colony Forming Unit; TNTC = Too Numerous To Count

Unless otherwise noted all analyses performed under NELAP certification have complied with all the requirements for the TNI standard.


Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320). For guidance and treatment recommendations, please visit

www.healthvermont.gov/water-contaminants.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:


Mary Celotti, Laboratory Director

If you have received this document in error or if you have questions about this report, please call 802-338-4724