



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

September 3, 2002

marc Maheux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

marc
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
08/02/02	1.4	1.2
08/07/02	1.3	1.2
08/16/02	1.3	1.2

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund
Alida I. Lund
Fluoridation Technician